

Net positive suction head (NPSH) :-

it is the energy available with water at inlet to the pump in the form of head which can be utilised in the form of suction height.

$$\left. \frac{P_i}{\rho g} \right|_{min} > \frac{P_v}{\rho g} \quad (\text{to avoid cavitation})$$

*
$$\boxed{NPSH = \frac{P_i}{\rho g} - \frac{P_v}{\rho g}} \text{ m}$$

{ Submerged
pump in
basewall
& cooling

Area affected by cavitation:-

- * In reaction turbine: At exit of runner or entry to draft tube.
- * In centrifugal pump: At the entry to impeller or pump.

Thoma's cavitation factor (σ)

$$\sigma = \frac{NPSH}{H} = \frac{\frac{P_1}{\rho g} - \frac{P_v}{\rho g}}{H}$$

$H \xrightarrow{\text{true}} \text{H}_{\text{atm}} - h_s - h_f - h_v$

$\sigma = \frac{\frac{P_{atm}}{\rho g} - h_s - h_f - h_v}{H}$

σ_c = critical Factor

$\sigma > \sigma_c$ (No. Cavitation)

$\sigma < \sigma_c$ (cavitation)

Q. 57 $H = 150 \text{ m}$ $\alpha = 0.2$

$$N_s = \frac{N \sqrt{\alpha}}{(H)^{3/4}}$$

$$\textcircled{2} N = 1450$$

$$N_s = 30$$

$$30 = \frac{1450 \sqrt{0.2}}{(H)^{3/4}}$$

$$H = 60.211 \text{ for each pump}$$

$$(H_m)_{\text{total}} = n \times (H_m)$$

$$150 = n \times 60.21$$

$$n = 2.49$$

$$n \approx 3 \text{ pump}$$

Q. 59 $Q = 0.10 \text{ m}^3/\text{s}$ $H = 30 \text{ m}$

$$r_c = 0.12$$

$$p_{atm} = 96 \text{ kPa}$$

$$P_v = 3 \text{ kPa}$$

$$h_f = 0.3$$

$$0.12 = \frac{96 \times 1000}{1000 \times 9.81} - h_s - 0.3 - \frac{3 \times 1000}{1000 \times 9.81}$$

$$0.12 = \frac{9.805}{1000} - h_s - 0.3$$

$$\textcircled{2} 0.12 = 9.805 - h_s - 0.3 - 0.3064$$

$$h_s = 5.58 \text{ m}$$

28

$$\frac{3}{2} \frac{0.15}{\text{feet}} = \frac{g - 1 - h_s}{40}$$

$$6 - 9 + 1 = -h_s$$

$$h_s = 2$$

$$\sigma_c = 0.15$$

$$H_v = 1$$

$$H_{atm} = g$$

$$h_s = ?$$

$$H_m = 40.$$

$$\Rightarrow \sigma_c = \frac{H_{atm} - h_s - H_p - H_v}{H_m}$$

$$0.15 = \frac{g - h_s - 1}{40}$$

$$h_s = 2 \underline{\underline{m}}$$