


Ch:- Basics of Control System.

What do you mean by system?




FAN without blades: No air flow: No proper o/p: Not a system

FAN with blades: Air flow: Proper o/p: It is a system

System:- It is nothing but group of elements (or) physical components arranged in such a way that it gives proper output to given i/p.



-The proper o/p may or may not be desired.

What is control system?



FAN with blades & : Air flow : Desired o/p : Control system with regulator

Control system : It is nothing but group of elements (OR) physical components arranged in such a way that it gives desired o/p by means of control / command / regulate either direct or indirect method to given i/p.




$$C(s) = R(s) \cdot G(s)$$

- Control system classified into two parts based on controlling action:-

(1) Open loop control system (OLCS)

(2) Closed loop control system (CLCS)


① Open loop control system [without feedback]



Eg:- FAN, tubelight, iron machine

- A control system in which controller action is not dependent on actual o/p of system is called open loop control system.

② Closed loop control system [with feedback]




Eg:- AC

- A control system in which controller action is dependent on actual o/p of system is called closed loop control system.

*What is feedback network?

- Feedback network is part of closed loop control system which brings actual o/p to the i/p & compares it with reference i/p according to comparison error will be generated and depending on that error controller action takes place.



Transfer function:



-The ratio of laplace transform of o/p to i/p considering all initial conditions are to be zero.

Initial conditions are to be zero means present o/p should not depend on past history of system. i.e. (past i/p & past o/p)

Eg:- If capacitor & inductors are used in system then both should be in relaxed condition.





$$C(s) = R(s) \cdot G(s)$$

$$T.F. = \frac{L[o/p]}{L[i/p]} \Big|_{I.C.=0}$$

$$O.L.T.F. = \frac{C(s)}{R(s)} = G(s)$$

↪ gain without feedback

* Closed loop control system



$$T.F. = \frac{L[o/p]}{L[i/p]} \Big|_{I.C. = 0}$$

$$T.F. = \frac{C[s]}{R[s]}$$

Here, $C(s) = G(s) \cdot E(s)$

$$E(s) = R(s) \pm B(s)$$

$$B(s) = C(s) \cdot H(s)$$

$$\therefore C[s] = G[s] \cdot E[s]$$

$$= G[s] \cdot [R[s] \pm B[s]]$$

$$= G[s] [R[s] \pm C[s] H[s]]$$

$$C[s] = G[s] R[s] \pm G[s] C[s] H[s]$$

$$C[s] [1 \mp G[s] H[s]] = G[s] R[s]$$

$$\frac{C[s]}{R[s]} = \frac{G[s]}{1 \mp G[s]H[s]}$$

→ +ve feedback

→ -ve feedback

(i) Positive feedback

$$\uparrow E[s] = R[s] + B[s]$$

Eg:- Schmitt trigger, oscillator, multivibrator

(ii) Negative feedback

$$\downarrow E[s] = R[s] - B[s]$$

Eg:- Amplifier

Advantage: Bandwidth is increased by same factors

Disadvantage: Overall gain is reduced by factor $1 + G[s]H[s]$

Gain with $\frac{G[s]}{1 + G[s]H[s]}$ = C.L.T.F. (Gain · Bandwidth = constant)
-ve


Gain without feedback	Gain with -ve feedback
O.L.T.F. = $\frac{C[s]}{R[s]} = G[s]$	C.L.T.F. = $\frac{C[s]}{R[s]} = \frac{G[s]}{1 + G[s]H[s]}$
O.L.C.S.	-ve feedback CLCS
OL Gain = G	CL gain = $\frac{G}{1 + GH}$
B.W. of OL CS = B.W. _{OL}	CLCS B.W. = B.W. _{CL}
Gain · B.W. _{OL} = constant	$\frac{G}{1 + GH} \cdot B.W._{CL} = \text{constant}$

$$G \times B.W._{OL} = \frac{G}{1+GH} \cdot B.W._{CL}$$

$$\star B.W._{CL} = B.W._{OL} (1+GH) \star$$

Because we know that

Gain = B.W. = Constant



- Any control system whether it is open loop or closed loop initially defined in terms of open loop controlsys i.e. given by

$$OLCS = GH(s) = \frac{k(1+sT_1)(1+sT_2)(1+sT_3) \dots}{s^n(1+sT_a)(1+sT_b)(1+sT_c) \dots}$$

→ Time constant form

k, T : system parameters

k : system gain

T : system time constant

$$s = \sigma + j\omega$$

n : Type of system

*Zeros

$$GH(s) \big|_{s=s_1} = 0$$

s_1 is zeros of the system

$$\boxed{N(s)=0} \rightarrow \text{zero of system}$$

$$(1+sT_1)(1+sT_2)(1+sT_3) \dots = 0$$

$$\text{Zeros: } s = -\frac{1}{T_1}, -\frac{1}{T_2}, -\frac{1}{T_3}, \dots$$

*Poles

$$OLTF = GH(s) \big|_{s=s_2} = \infty$$

s_2 is poles of the system

$$\boxed{D(s)=0} \rightarrow \text{poles of system}$$

$$s^n(1+sT_a)(1+sT_b)(1+sT_c) \dots = 0$$

$$\text{Poles: } s=0, 0, 0, \dots \text{ } n \text{ times, } -\frac{1}{T_a}, -\frac{1}{T_b}, -\frac{1}{T_c}, \dots$$

*Order

Total number poles in s-plane

*Type

Total number poles @ origin in s-plane

★ OLTF and should be
time-constant form ★

*Gain (k)

T C F

time constant form

To find system gain(k)
given OLTF should be in
time-constant form


NOTES:-

-Type & order of system is defined
only for open loop transfer function

-It is not defined for closed loop
T.F. If CLTF is given then first
convert it into OLTF then find order
and type

$$Q:- G_H(s) = \frac{10(s+2)(s+3)}{s^2(s+1)(s+4)(s+5)^2}$$

Above is pole-zero s-plane form



$$\text{TCF: } G_H(s) = \frac{\overset{k}{10 \times 2 \times 3} \left(1 + \frac{s}{2}\right) \left(1 + \frac{s}{3}\right)}{\cancel{4} \times \cancel{8} \times 5 \cdot s^2 (1+s) \left(1 + \frac{s}{4}\right) \left(1 + \frac{s}{5}\right)^2}$$

$$k = 3/5$$

$$Q:- \text{T.F.} = \frac{15(s+2)(s+4)}{s^2(s^2+2s+1)} \quad \text{For given OLS (open loop system).}$$


Find system gain, type & order of system

Type: Total no. of poles at origin

$$\text{Type} = (2)$$

Order = Total no. of poles in system

$$\text{Order} = (4)$$



$$\text{TCF: } G_H(s) = \frac{15 \times 2 \times 4 \left(1 + \frac{s}{2}\right) \left(1 + \frac{s}{4}\right)}{s^2 (s+1)^2}$$


(time constant form)

$$k = 120$$

Q:- For given OLCs find order, type & gain

$$\frac{C(s)}{R(s)} = \frac{10(s+3)^2}{s^3(s+2)^2(s+10)}$$

Order = 6
Type = 3



$$k = \frac{10 \times 3 \times 3}{2 \times 2 \times 10} \frac{(1 + \frac{s}{3})^2}{s^3(1 + \frac{s}{2})^2(1 + \frac{s}{10})}$$

$$k = \frac{9}{4}$$


★
Q:- $\frac{C(s)}{R(s)} = \frac{20(s+5)(s+2)}{s^2(s^3+5s^2+6s)}$

$$\frac{C(s)}{R(s)} = \frac{20(s+5)(s+2)}{s^2 \cdot s(s^2+5s+6)} = \frac{20(s+5)(s+2)}{s^3(s^2+5s+6)} = \frac{20(s+5)(s+2)}{s^3(s+2)(s+3)}$$

Type: 3

Order: 4

$$k = \frac{20 \times 5 \times 2 \left[1 + \frac{s}{5}\right] \left[\cancel{1 + \frac{s}{2}}\right]}{s^3 \left[\cancel{1 + \frac{s}{2}}\right] \left[1 + \frac{s}{3}\right] \cdot 2 \times 3}$$




$$k = \frac{100}{3}$$

Any system is defined in form of open loop transfer fon. COLTF

CONTROL SYSTEM

Open loop control system




$$OLTF = \frac{C(s)}{R(s)} = G(s)$$

Closed loop control system

O.L.C.S. Gain
is $G(s)H(s)$

Unity feedback system

$$H(s) = 1$$




$$H(s) = 1$$

OLTF of UFCS = $G(s)$

$$C.L.T.F. = \frac{C(s)}{R(s)} = G(s)$$


Non-unity feedback sys.

$$H(s) \neq 1$$



OLTF of NUFCS = $G(s)H(s)$

$$\frac{C(s)}{R(s)} = C.L.T.F. = \frac{G(s)}{1 \pm G(s)H(s)}$$



$$\text{loop gain} = G(s)H(s)$$

Q:- Find type and order for CLTF of Unity gain feedback system.

$$\frac{C(s)}{R(s)} = \frac{2s+5}{s^5+s^4+6s^3+7s^2+2s+5}$$

⇒ Here CLTF is given

$$CLTF = \frac{G}{1+G} \quad \text{--- (1)}$$

But for order & type we require OLTF of UFS i.e. $G(s)$

$$OLTF = G(s)$$

Now, from eqⁿ (1)

$$(2s+5)(1+G) = (s^5+s^4+6s^3+7s^2+2s+5)G$$

$$2s+5 + (2s+5)G = (s^5+s^4+6s^3+7s^2+2s+5)G$$

$$G(s^5+s^4+6s^3+7s^2+2s+5 - (2s+5)) = 2s+5$$

$$G = \frac{2s+5}{s^5+s^4+6s^3+7s^2+2s+5 - (2s+5)}$$

$$G = \frac{2s+5}{s^5+s^4+6s^3+7s^2-} = \frac{2s+5}{s^2[s^3+s^2+6s+7]}$$

Type: 2

Order: 5

NOTE:

$$\text{CLTF of UFS: } \frac{N(s)}{D(s)}$$

Subtract $N(s)$ from $D(s)$

$$\text{OLTF of UFS: } \frac{N(s)}{D(s) - N(s)}$$

Add $N(s)$ into $D(s)$

$$\text{CLTF of UFS: } \frac{N(s)}{D(s) - N(s) + N(s)}$$

* Review of Laplace Transform

Only for causal system

$$t > 0$$

$$u(t)$$

s

①

$$x(t)$$

$$\longleftrightarrow$$

$$X[s] = \int_{-\infty}^{\infty} x(t) e^{-st} dt$$

②

$$L[s(t)]$$

$$\longleftrightarrow$$

$$1$$

③

$$L[u(t)]$$

$$\longleftrightarrow$$

$$1/s$$

$$L[t^n u(t)]$$

④

$$L[r(t)]$$

$$\longleftrightarrow$$

$$1/s^2$$

$$L[t u(t)]$$

⑤

$$L[t^n u(t)]$$

$$\longleftrightarrow$$

$$\frac{n!}{s^{n+1}}$$

$$\textcircled{6} \quad L[e^{-at}u(t)] \longleftrightarrow \frac{1}{s+a}$$

$$\textcircled{7} \quad L[e^{at}u(t)] \longleftrightarrow \frac{1}{s-a}$$

$$\textcircled{8} \quad L[e^{-at}x(t)] \longleftrightarrow X[s+a]$$

$$\textcircled{9} \quad L[e^{at}x(t)] \longleftrightarrow X[s-a]$$

$$\textcircled{10} \quad L[\sin bt] \longleftrightarrow \frac{b}{s^2+b^2}$$

$$\textcircled{11} \quad L[\cos bt] \longleftrightarrow \frac{s}{s^2+b^2}$$


$$\textcircled{12} \quad L[e^{-at}\sin bt] \longleftrightarrow \frac{b}{(s+a)^2+b^2}$$

$$\textcircled{13} \quad L[e^{-at}\cos bt] \longleftrightarrow \frac{s+a}{(s+a)^2+b^2}$$

$$\textcircled{14} \quad L[t \cdot e^{-at}u(t)] \longleftrightarrow \frac{1}{(s+a)^2}$$

* Time constant of the system (IMP)

Consider given series RC circuit




Elements	t	s
	$R (\Omega)$	$R (\Omega)$
	$C (F)$	$\frac{1}{Cs} (\Omega)$
	$L (H)$	$sL (\Omega)$

$$T.F. = \frac{L[o/p]}{L[i/p]} \Big|_{I.C. = 0}$$

$$C(s) = \frac{1/sC}{R + 1/sC} \cdot R(s)$$

$$T.F. = \frac{C(s)}{R(s)} = \frac{1}{1 + sRC} = \frac{1}{s\tau + 1} = \frac{1}{\tau \left(\frac{1}{\tau} + s \right)}$$

$$\text{Let } \tau = RC$$




$$\tau = -1$$


Real part of dominant pole

Q Ex:- $\frac{1}{s+2} = \frac{1}{2(1+\frac{s}{2})} = \frac{1}{(\tau s+1)}$


$$\tau = 1/2$$



Ex:- $\frac{1}{s+5} \quad \tau = \frac{-1}{-5} = \frac{1}{5}$



$$C(s) = \frac{Y}{1+s\tau} R(s)$$



Impulse $\longrightarrow$ Impulse response

Unit step $\longrightarrow$ Unit step response

Ramp $\longrightarrow$ Ramp response

Parabola $\longrightarrow$ Parabola response

* Impulse Response

$$r(t) = \delta(t)$$

$$R(s) = 1$$

$$C(s) = \frac{1}{1+s\tau} = \frac{1}{\tau} \cdot \frac{1}{(s + 1/\tau)}$$

$$C(t) = \frac{1}{\tau} e^{-t/\tau} \rightarrow \tau = RC = \text{time constant}$$

* Time constant

Time constant is defined only for stable system


$$t$$

$$e^{-t/\tau}$$


$$s$$

s-plane

$$\tau = \frac{1}{\text{Real part of dominant pole}}$$

$$e^{-2t} \leftrightarrow \tau = \frac{1}{2} = \frac{1}{s+2}$$


NQW, $C(t) = \frac{1}{\tau} e^{-t/\tau} u(t)$




$$C(t)|_{t=\tau} = \frac{1}{\tau} e^{-1} = 0.3678 \cdot \frac{1}{\tau}$$

$$C(t)|_{t=5\tau} = \frac{1}{\tau} e^{-5} = 0.006738 \approx 0$$

* Dominant pole and Insignificant pole

$$GH(s) = \frac{1}{(s+1)(s+10)} = \frac{C(s)}{R(s)}$$




- The pole which is very close to imaginary axis is called as dominant pole.
- Dominant pole has large time constant. So it is not good pole. It affects the system so we have to compensate with by adding zero ^{at} the same location.
- Insignificant pole: The poles which lies on left hand most side in s-plane is nothing but insignificant pole.
- Insignificant pole has less time constant. So good performance and hence best pole.

$$\tau_{D.P.} \geq 5 \tau_{I.P.}$$

$$I.P. \text{ Location} \leq 5 (\text{Dominant Pole location})$$

$$GH(s) = \frac{1}{(s+1)(s+10)} = \frac{C(s)}{R(s)}$$



$$\frac{C(s)}{R(s)} = \frac{1}{(s+1)(s+10)}$$

for I.R., $r(t) = 8(t)$

$$R(s) = 1$$



$$C(s) = \frac{1}{(s+1)(s+10)}$$

$$C(s) = \frac{A}{s+1} + \frac{B}{s+10}$$

$$= \left(\frac{1}{s+1} - \frac{1}{s+10} \right) \frac{1}{9}$$

$$c(t) = \left[\frac{1}{9} e^{-t} - \frac{1}{9} e^{-10t} \right] u(t)$$

$$c(t) = \frac{1}{9} e^{-t} u(t) - \frac{1}{9} e^{-10t} u(t)$$



-The best pole is insignificant poles because it gives very quick response and more relatively stable because of the dominant pole system response becomes slow and system becomes less relatively stable.

-Insignificant pole (I.P.) is neglected because even if I.P. are neglected there is no much change in system response.

-We can neglect I.P. only if OLTF and eqⁿ should be in T.C.F. (time constant form)

$$GH(s) = \frac{1}{(s+1)(s+10)}$$

$$GH(s) = \frac{1}{10(s+1)\left(1+\frac{s}{10}\right)}$$

D.P. I.P.

Neglecting I.P.

$$GH(s) = \frac{0.1}{s+1}$$

NOTE:- The I.P. must be neglected only in T.C.F. → time constant form

Q:- Find the eqⁿ transfer function of open loop system.


$$\frac{C(s)}{R(s)} = \frac{1}{(s+1)(s+10)(s+100)}$$

(A) $\frac{1}{s+1}$

(B) $\frac{1}{(s+1)(s+10)}$

(C) $\frac{0.01}{(s+1)(s+10)}$

(D) $\frac{0.001}{(s+1)}$




$$\tau_{D.P.} \geq 5 \tau_{I.P.}$$

$$\therefore \frac{I(s)}{R(s)} = \frac{1}{(s+1) \cdot 10 \left(1 + \frac{s}{10}\right) (100) \left(1 + \frac{s}{100}\right)}$$

$$\frac{I(s)}{R(s)} = \frac{0.001}{s+1} \quad (D)$$

2nd definition of transfer function:

It is laplace transform of impulse response by considering all initial conditions ^{are} to ^{be} zero.



$$R(s) = 1$$


Def:- ①
$$T.F. = \frac{L[o/p]}{L[i/p]} \Big|_{I.C.=0}$$

②
$$T.F. = \frac{L[\text{Impulse response}]}{L[\text{Impulse}]} \Big|_{I.C.=0}$$

$$T.F. = L[\text{Impulse response}] \Big|_{I.C.=0}$$

Impulse response gives system behaviour or characteristics of system bcz. impulse response consists only system parameters, no input term is present in impulse response

Hence impulse response is called system response or natural response or free forced response



(1) Impulse response

$$r(t) = \delta(t)$$

$$R(s) = 1$$

$$\frac{C(s)}{R(s)} = \frac{1}{(s+1)}$$

$$C(s) = \frac{R(s)}{s+1}$$

$$C(s) = \frac{1}{s+1}$$

$$c(t) = e^{-t} u(t) \Rightarrow \text{I.R.}$$

(2) Unit step response

$$r(t) = u(t)$$

$$R(s) = 1/s$$

$$C(s) = \frac{R(s)}{s+1}$$

$$C(s) = \frac{1}{s(s+1)} = \frac{1}{s} - \frac{1}{s+1}$$

$$c(t) = (1 - e^{-t}) u(t)$$

$$c(t) = \underbrace{u(t)}_{\substack{\downarrow \\ \text{input is} \\ \text{these}}} - e^{-t} \underbrace{u(t)}_{\substack{\downarrow \downarrow \\ \text{USR}}}$$

Therefore only I.R. is system response.

* Stability

- If the system response $c(t)$ is finite value as $t \rightarrow \infty$ then system is said to be stable.

$$c(t) \Big|_{t \rightarrow \infty} = \text{finite (including zero)} \Rightarrow \text{stable}$$


$$= \text{infinite } (\infty) \Rightarrow \text{unstable}$$

If the system response $c(t)$ is infinite value as $t \rightarrow \infty$ then system is said to be unstable.

If $c(t)|_{t \rightarrow \infty} = \text{finite} = \text{stable}$

System Response = Impulse response

Q:- For the given RC circuit. Find the T.F. locate poles & zeros in s-plane. Find system response, and check system stability




$$\text{T.F.} = \frac{L[o/p]}{L[i/p]} \Big|_{\text{I.C.}=0}$$

$$C(s) = \frac{1/sC}{R + 1/sC} \cdot R(s)$$

$$\text{T.F.} = \frac{C(s)}{R(s)} = \frac{1}{1 + sCR} = \frac{1}{1 + sT}$$

$$T = RC \text{ (sec.)}$$

$$\text{Pole: } s = -1/T$$




for system response

$$r(t) = \delta(t)$$

$$R(s) = 1$$

$$C(s) = \frac{1}{1 + sT} = \frac{1}{T(s + 1/T)}$$

$$c(t) = \frac{1}{T} e^{-t/T} u(t)$$




$$c(t) = \frac{1}{T} e^{-t/T} u(t)$$

$$c(t)|_{t \rightarrow \infty} = \frac{1}{T} e^{-\infty} u(t) = \frac{1}{T} \cdot \frac{1}{e^{\infty}} u(t) = 0 \Rightarrow \text{finite}$$

STABLE

Q:- For the series RLC circuit. Find overall transfer function. Find system response, if $R=0$, $L=1H$ and $C=1F$. Then check system stability locate poles & zeros in s-plane and also calculate system time constant

(b) If $R=1\Omega$, $L=1H$ & $C=1F$ then find system response, T.F., locate poles & zeros, system time constant & stability.



$$C(s) = \frac{1/sC}{R + sL + 1/sC} R(s)$$

$$\frac{C(s)}{R(s)} = \frac{1}{s^2 LC + RCs + 1}$$

$$\frac{C(s)}{R(s)} = \frac{1/LC}{s^2 + s\frac{R}{L} + \frac{1}{LC}}$$

(a) If $R=0$, $L=1H$ & $C=1F$

$$\frac{C(s)}{R(s)} = \frac{1}{s^2 + 1}$$


Poles: $\pm j$

Time constant: $\frac{-1}{\text{Real part of dominant pole}} = \frac{-1}{0} = \infty$

$$\therefore C(s) = \frac{1}{s^2 + 1} R(s)$$


for system response $\Rightarrow R(s) = 1$

$$C(s) = \frac{1}{s^2 + 1} \quad \therefore c(t) = \sin t \cdot u(t)$$



Comparing it with $c(t) = \sin \omega t u(t)$

$$\omega = 1 \text{ rad/sec.}$$



= value will be finite $[-1, 1]$

= stable

(b) $R = 1 \Omega$, $L = 1 \text{ H}$ & $C = 1 \text{ F}$

$$\frac{C(s)}{R(s)} = \frac{1}{s^2 + s + 1}$$

$$\frac{C(s)}{R(s)} = \frac{1}{s^2 + s + 1}$$

$$\text{Poles: } -\frac{1 \pm \sqrt{3}j}{2}$$


$$\text{Time constant: } -\frac{1}{\pm 1/2} = 2 \text{ sec.}$$

$$\frac{C(s)}{R(s)} = \frac{1}{(s + 1/2)^2 + (\sqrt{3}/2)^2}$$


$$c(t) = \frac{2}{\sqrt{3}} e^{-t/2} \sin \frac{\sqrt{3}}{2} t \cdot u(t)$$

$\downarrow$ exp. decay $\rightarrow$ sinusoidal function


$$\omega = \sqrt{3}/2 \text{ rad/sec.}$$



Non-repeated complex conjugate poles on L.H.S.



*Stability



① $\frac{1}{s+a}$

② $\frac{1}{s-a}$

③ $\frac{1}{(s+c)^2}$

④ $\frac{1}{(s-c)^2}$

⑤ $\frac{1}{s}$

⑥ $\frac{1}{s^2}$

⑦ $\frac{1}{(s+a)^2+b^2}$

⑧ $\frac{1}{(s-a)^2+b^2}$

⑨ $\frac{1}{s^2+b^2}$

⑩ $\frac{1}{(s^2+e^2)^2}$

⑪ $\frac{1}{(s+a)(s+b)}$

⑫ $\frac{1}{(s-a)(s-b)}$



● non-repeated pole or simple real pole:

● (1) $\frac{C(s)}{R(s)} = \frac{1}{s+a}$

● For system response,

● $R(s) = 1$, $C(s) = \frac{1}{s+a}$

● $c(t) = e^{-at} \cdot u(t)$



● $w = \text{No imaginary pole} = 0$

● Stability

● $c(t)|_{t \rightarrow \infty} = e^{-at} \cdot u(t) = 0 = \text{finite} - \text{stable}$

● (2) $\frac{C(s)}{R(s)} = \frac{1}{(s+a)(s+b)}$; $a > b$



● For system response,

● $R(s) = 1$; $C(s) = \frac{1}{(s+a)(s+b)}$

● $C(s) = \frac{k_1}{s+a} + \frac{k_2}{s+b}$

● $c(t) = (k_1 e^{-at} + k_2 e^{-bt}) u(t)$

$\downarrow$ $\downarrow$
 $\tau = 1/a$ $\tau = 1/b$



stability

$c(t)|_{t \rightarrow \infty} = (k_1 e^{-at} + k_2 e^{-bt}) u(t)$
 $= \text{Finite} \Rightarrow \text{stable}$

Repeated real poles:-




$$(1) \frac{C(s)}{R(s)} = \frac{1}{(s+a)^2}$$

For system response,

$$C(s) = \frac{1}{(s+a)^2}$$

$$c(t) = t \cdot e^{-at} u(t)$$

$$\downarrow$$
$$\tau = 1/a$$



stability:-

$$c(t) \Big|_{t \rightarrow \infty} = t \cdot e^{-at} \cdot u(t)$$

$$= \infty \cdot 0 \cdot u(t)$$

$$= 0$$

= finite $\Rightarrow$ stable

Repeated complex conjugate pole:-

$$\frac{C(s)}{R(s)} = \frac{1}{(s+a)^2 + b^2}$$

For system response,



$$R(s) = 1$$

$$C(s) = \frac{1}{b} \cdot \frac{b}{(s+a)^2 + b^2}$$

$$c(t) = \frac{1}{b} e^{-at} \sin bt u(t)$$

$$\downarrow$$

$$\tau = 1/a, \quad \omega = b \text{ rad/sec.}$$



* stability

$$c(t)|_{t \rightarrow \infty} = \frac{1}{b} e^{-\infty} \sin b \infty u(t)$$

$$= 0 = \text{Finite}$$

stable



* Non-repeated pole OR simple real pole: X

$$1. \frac{C(s)}{R(s)} = \frac{1}{s+a}$$

For system response,

$$R(s) = 1, \quad C(s) = \frac{1}{s+a}$$

$$c(t) = e^{-at} \cdot u(t)$$



$\omega = \text{No imaginary pole} = 0$

* Stability

$$c(t)|_{t \rightarrow \infty} = e^{-\infty} u(t) = 0 = \text{Finite}$$

stable

Right hand side pole

$$1. \frac{C(s)}{R(s)} = \frac{1}{s-a}$$

For system response, $R(s)=1$

$$C(s) = \frac{1}{s-a}$$



$$c(t) = e^{at} \cdot u(t)$$

$\omega=0$ = No imaginary poles

$$\tau = -\frac{1}{a}$$

* Stability

$$c(t)|_{t \rightarrow \infty} = e^{\infty} u(\infty) = \infty \Rightarrow \text{Not stable}$$




$$2. \frac{C(s)}{R(s)} = \frac{1}{(s-a)(s-b)}$$

$$C(s) = \frac{k_1}{s-a} + \frac{k_2}{s-b}$$

$$c(t) = (k_1 e^{at} + k_2 e^{bt}) u(t)$$

* stability

$$c(t)|_{t \rightarrow \infty} = (k_1 e^{\infty} + k_2 e^{\infty}) u(\infty) = \infty \Rightarrow \text{Not stable}$$




$$3. C(s) = \frac{1}{(s-a)^2}$$

$$c(t) = t \cdot e^{at} \cdot u(t)$$

$$\tau = -1/a, \omega = 0$$

* stability


$$c(t)|_{t \rightarrow \infty} = \infty \Rightarrow \text{Not stable}$$



$$4. \frac{C(s)}{R(s)} = \frac{1}{(s-a)^2 + b^2}$$


$$c(t) = \frac{1}{b} e^{at} \sin bt$$

$$T = -1/a, \quad \omega = b \text{ rad/sec.}$$



*stability

$$c(t) |_{t \rightarrow \infty} = \infty \Rightarrow \text{Not stable}$$





Non-repeated poles at origin

$$\frac{C(s)}{R(s)} = \frac{1}{s}$$

$$C(s) = \frac{1}{s}$$

$$c(t) = u(t)$$





$\Rightarrow$ steady state
Marginally stable
 $T = \infty$
 $\omega = 0$

Repeated poles at origin

$$\frac{C(s)}{R(s)} = \frac{1}{s^2}$$

$$c(t) = t u(t)$$



*stability



$$c(t) |_{t \rightarrow \infty} = \infty \Rightarrow \text{Not stable}$$

$$\frac{C(s)}{R(s)} = \frac{1}{s^2 + b^2}$$

$$c(t) = \frac{1}{b} \sin bt$$

$$\tau = \infty$$

$$\omega = b \text{ rad/sec.}$$





constant amplitude
Marginally stable

$$\frac{C(s)}{R(s)} = \frac{1}{(s^2 + b^2)^2}$$

$$c(t) = \frac{1}{b} \cdot t \sin bt \, u(t)$$

$$\tau = \infty$$

$$\omega = b \text{ rad/sec.}$$



linearly increasing
Unstable

*Observation from above cases:-

1. Left hand side poles [repeated or non-repeated]
system is always STABLE.
 2. Right hand side pole [repeated or non-repeated]
system is always UNSTABLE.
 3. Non-repeated poles at origin, system is
Marginally Stable.
 4. Repeated pole at origin, system becomes UNSTABLE.
 5. Non-repeated pole on imaginary axis, system
becomes Marginally Unstable.
 6. Repeated poles on imaginary axis, system becomes
UNSTABLE.
-

s Term


Time Response

1) Real part




expon. function

2) Imag. part



sine function

3) Real + Imag.




exp. x sine function

4) Repeated



Ramp

Q:-



$$\frac{C(s)}{R(s)} = \frac{s+3}{(s+1)(s+2)(s+4)}$$

For system response,

Take $R(s) = 1$

$$C(s) = \frac{s+3}{(s+1)(s+2)(s+4)}$$

$$C(s) = \frac{k_1}{s+1} + \frac{k_2}{s+2} + \frac{k_3}{s+4}$$

$$c(t) = (k_1 e^{-t} + k_2 e^{-2t} + k_3 e^{-4t}) u(t) = \left(\frac{2}{3} e^{-t} - \frac{1}{2} e^{-2t} - \frac{1}{6} k_3 e^{-4t} \right) u(t)$$

For stability,

$$c(t)|_{t \rightarrow \infty} = 0 = \text{finite} \Rightarrow \text{stable}$$

NOTE:-


To find

system response
system time constant
system stability

We are considering
any poles but
not zeros.

Above note can be concluded by taking
following three cases:-

Case: 1



Change zero location to $s = -3$ to $s = -5$

$$\frac{C(s)}{R(s)} = \frac{(s+5)}{(s+1)(s+2)(s+4)}$$

For system response

$$R(s) = 1$$

$$C(s) = \frac{(s+5)}{(s+1)(s+2)(s+4)}$$


$$C(s) = \frac{A}{s+1} + \frac{B}{s+2} + \frac{C}{s+4}$$

$$C(t) = (k_1 e^{-t} + k_2 e^{-2t} + k_3 e^{-4t}) u(t)$$

$$C(t) \big|_{t \rightarrow \infty} = 0 \Rightarrow \text{finite (stable)}$$

Case:-2

change zero from -3 to +1



$$\frac{C(s)}{R(s)} = \frac{(s-1)}{(s+1)(s+2)(s+4)}$$

$$R(s) = 1$$

$$\therefore C(s) = \frac{s-1}{(s+1)(s+2)(s+4)}$$

$$C(s) = \frac{A}{s+1} + \frac{B}{s+2} + \frac{C}{s+4}$$


$$\therefore c(t) = (k_1 e^{-t} + k_2 e^{-2t} + k_3 e^{-4t}) u(t)$$

* for stability

$$c(t)|_{t \rightarrow \infty} = 0 \Rightarrow \text{finite}$$

stable

Case:-3 Add one single pole at $s=1$



$$\frac{C(s)}{R(s)} = \frac{s+3}{(s+1)(s+2)(s+4)(s-1)}$$

$$R(s) = 1$$

$$C(s) = \frac{A}{s+1} + \frac{B}{s+2} + \frac{C}{s+4} + \frac{D}{s-1}$$

$$c(t) = (k_1 e^{-t} + k_2 e^{-2t} + k_3 e^{-4t} + k_4 e^t) u(t)$$

* Stability

$$c(t)|_{t \rightarrow \infty} = \infty \Rightarrow \text{unstable}$$

τ = not defined

Whole finding system response, time constant & stability we are considering only poles but not zeros because system response consists only poles response term. There is no zeros response term exists in the system response. **NOTE**

[at any location]
Addition of zeros in s-plane will not affect system response, system time constant and system stability, it will change only amplitude of response.

Addition of poles in s-plane will affect system stability, system response and system time constant

If addition of poles in L.H.S. of s-plane then system becomes stable.

But if addition of poles is R.H.S. it will make system unstable.

* Characteristics of system


Ex:-
$$\frac{C(s)}{R(s)} = \frac{s-10}{(s+1)(s+5)}$$

For system response:-

$$R(s) = 1$$

$$C(s) = \frac{s-10}{(s+1)(s+5)}$$

$$c(t) = (k_1 e^{-t} + k_2 e^{-5t}) u(t)$$




- Denominator terms decides the characteristics of system not numerator terms so for characteristics eqⁿ we are considering denominator term = 0.

- The denominator of the transfer function makes = 0 then it is called characteristic eqⁿ.

- Characteristic eqⁿ gives system behaviour or characteristics of system.

- Consider closed loop control system,



$$\frac{C(s)}{R(s)} = \frac{G(s)}{1 \pm G(s)H(s)} = \frac{\text{C.L. zeros}}{\text{C.L. poles}}$$

$$1 \pm G(s)H(s) = 0 \rightarrow \text{Roots of C.E.} = \text{C.L. poles}$$

↓
closed loop

↑ characteristics eqⁿ
of C.L.T.F.

$$\text{O.L.T.F. of CLCS} = GH(s) = \frac{KN(s)}{D(s)} = k \frac{\text{OL zeros}}{\text{OL poles}}$$

$$1 \pm GH(s) = 0 \rightarrow \text{CL poles}$$


Considering -ve feedback.

$$1 + GH(s) = 0$$

$$1 + k \frac{\text{OL zeros}}{\text{OL poles}} = 0 \rightarrow \text{C.L. poles}$$

$$\boxed{\text{O.L. poles} + \text{k.O.L. zeros} = 0} \rightarrow \text{c.L. poles}$$

Open loop system



$$\text{O.L.T.F.} = \frac{C(s)}{R(s)} = G(s) = \frac{\text{O.L. zeros}}{\text{O.L. poles}}$$

NOTE:-

- O.L. zeros will not affect open loop system stability
- O.L. poles will affect open loop system stability
- C.L. zeros will not affect closed loop sys. stability
- C.L. poles will affect closed loop sys. stability.
- O.L. zeros will affect closed loop system stability.
- O.L. poles will affect closed loop system stability

IMP points to be remembered:-

1. In the system response exponential terms are real part of the poles
2. Sine or cosine function are pure imaginary part of the pole
3. t -terms in the response represent repeated nature of the pole.
4. To get the time response constant for the response compare the response with $e^{-t/\tau}$.
5. The system time constant is nothing but dominant pole time constant and it should have largest value.
6. If one or more poles lies in the left of s -plane at different location then the system response is exponential decay irrespective of position of zeros and system is stable.
7. When poles lies on imaginary axis which are non-repeated then system response is constant amplitude & constant frequency of oscillation.
8. Any system which produces constant amplitude and frequency of oscillation then it is called marginally stable system or undamped system.
9. In complex conjugate poles, the real part will give time constant and imaginary part will give frequency of oscillation.

10. Whenever the poles are complex conjugate in the left of s-plane then the system response is exponential decay and frequency of oscillation, which are called damped oscillation.


11. Any system which produces damped oscillation is stable system.

12. Whenever more than one poles lies in Right of s-plane at any location at different location on real axis then the system response is exponential rise to infinity & system becomes unstable.

13. Whenever the poles are complex conjugate on right of s-plane then the system response is exponential increasing & frequency of oscillation and system becomes unstable.

* Transfer function of electrical networks:-

Q:- Find transfer function to given electrical network



$$C(s) = \frac{Z_2}{Z_1 + Z_2} R(s)$$

$$\text{T.F.} = \frac{L[o/p]}{L[i/p]} \Big|_{I.C.=0}$$


$$\text{T.F.} = \frac{C(s)}{R(s)} = \frac{V_o(s)}{V_i(s)} = \frac{Z_2}{Z_1 + Z_2}$$

$$R \rightarrow Z = R \Omega$$

$$L \rightarrow Z = sL \Omega$$

$$C \rightarrow Z = 1/sC \Omega$$

Q:- Find T.F. to given ckt:-



$$Z_1 = R \parallel L$$

$$Z_1 = \frac{R \cdot sL}{R + sL} \quad \& \quad Z_2 = \frac{1}{sC}$$

$$\begin{aligned} \therefore \frac{V_o(s)}{V_i(s)} &= \frac{Z_2}{Z_1 + Z_2} = \frac{\cancel{1} (R + sL)}{sC (R + sL)} \cdot \frac{\cancel{1/sC} + \frac{R \cdot sL}{R + sL}}{\cancel{1/sC} + \frac{R \cdot sL}{R + sL}} \\ &= \frac{\cancel{R + sL}}{\cancel{s^2 RLC}} \cdot \frac{R + sL}{R + sL + s^2 RLC} \\ &= \frac{R + sL}{s^2 RLC + sL + R} \end{aligned}$$

$$s^2 RLC + sL + R = 0$$

$$s = \frac{-L \pm \sqrt{L^2 - 4R^2LC}}{2RLC}$$

$$s = \frac{-L \pm \sqrt{L^2 - 4R^2LC}}{2RLC} = \text{complex conjugate pole}$$

For DC gain

$$\downarrow$$

$$f = 0$$

$$\downarrow$$


$$\omega = 2\pi f = 0$$

$$\downarrow$$

$$s = j\omega = 0$$

for DC gain put $s=0$ in given T.F.

∴ Here, DC gain = $\frac{R}{R} = 1$



$$Z_1 = 1 + s \parallel 1 + \frac{1}{s}$$

$$Z_2 = 1 + \frac{1}{s}$$

$$= \frac{(1+s)(1+\frac{1}{s})}{1+s+1+\frac{1}{s}}$$

$$= \frac{1 + \frac{1}{s} + s + 1}{2 + s + \frac{1}{s}}$$

$$= \frac{2 + \cancel{s} + \frac{1}{s}}{2 + \cancel{s} + \frac{1}{s}}$$

$$Z_1 = 1$$

$$\frac{V_o(s)}{V_i(s)} = \frac{Z_2}{Z_1 + Z_2} = \frac{1 + \frac{1}{s}}{1 + 1 + \frac{1}{s}} = \frac{s+1}{2s+1}$$

for DC gain

put $s = 0$

$$\underline{\text{DC gain} = 1}$$

* Transfer function of differential eqⁿ:-

Q:- Find the T.F. of the given system where x is input and y is output

$$\frac{d^3 y}{dt^3} + 5 \frac{d^2 y}{dt^2} + 7 \frac{dy}{dt} + 9y = 2 \frac{dx}{dt} + x(t-T)$$

Sol:- Taking laplace transform:-

$$s^3 Y(s) + 5s^2 Y(s) + 7s Y(s) + 9Y(s) = 2sX(s) + e^{-Ts} X(s)$$

$$\frac{Y(s)}{X(s)} = \frac{2s + e^{-Ts}}{s^3 + 5s^2 + 7s + 9}$$

Q:- Write differential eqⁿ to given transfer function


$$T.F. = \frac{Y(s)}{X(s)} = \frac{2s + 3}{s^2 + 5s + 6}$$

$$Y(s)s^2 + 5sY(s) + 6Y(s) = 2sX(s) + 3X(s)$$

Taking inverse laplace transform,

$$\frac{d^2 y}{dt^2} + 5 \frac{dy}{dt} + 6y = 2 \frac{dx}{dt} + 3x$$

* Transfer function to the system ^{signal} response.



$$S.R. = I.R.$$


- | | | |
|--------------|---|----------------------|
| 1) Impulse | → | ① Impulse response |
| 2) Unit step | → | ② Unit step response |
| 3) Ramp | → | ③ Ramp response |
| 4) Parabola | → | ④ Parabola response |

$$T.F. = \frac{L[o/p]}{L[i/p]} \Big|_{I.C.=0}$$

$$c(t) = s_1(t) * g(t)$$


$$C[s] = R[s] \cdot G[s]$$

NOTE:-



Q:- Unit step response of the system is $y(t) = \frac{5}{2} - \frac{5}{2}e^{-2t} + 5t$, $t \geq 0$
 its T.F. is _____.

Sol:- $y(t) = \frac{5}{2} - \frac{5}{2}e^{-2t} + 5t$; $t \geq 0$




$$T.F. = \frac{L[\text{unit step response}]}{L[\text{unit step}]} \Big|_{I.C.=0}$$

$$= \frac{\frac{5}{2s} - \frac{5}{2(s+2)} + \frac{5}{s^2}}{1/s}$$

$$= \frac{5s(s+2) - 5s^2 + 5(s+2)}{2s^2(s+2)} = \frac{10s + 5(s+2)}{2(s+2)s} = \frac{10(s+1)}{s(s+2)}$$

Q:- The I.R. of the system is $c(t) = -4e^{-t} + 6e^{-2t}; t \geq 0$
equivalent S.R. is _____.

Sol:-



~~P.E.G~~ S.R. = $\int_{-\infty}^t (\text{I.R.}) dt$


$$= \int_{-\infty}^t (-4e^{-t} + 6e^{-2t}) dt = \int_0^t (-4e^{-t} + 6e^{-2t}) dt$$

$$= \left[+4e^{-t} + \frac{6e^{-2t}}{-2} \right]_0^t$$

$$= 4e^{-t} - 3e^{-2t} - [4 - 3]$$

$$\text{S.R.} = (4e^{-t} - 3e^{-2t} - 1)u(t)$$

2nd Method:-



$$C[s] = R[s] \cdot G[s]$$

For S.R. $\Rightarrow R[s] = 1/s$

$$\boxed{C[s] = \frac{1}{s} \cdot G[s]} \quad \text{--- (1)}$$

Now, for I.R. $\Rightarrow R(s) = 1$

$$C[s] = G[s]$$

$$G[s] = \frac{-4}{(s+1)} + \frac{6}{(s+2)} \quad \text{--- (2)}$$

$$C[s] = \frac{-4}{s(s+1)} + \frac{6}{s(s+2)}$$

$$\frac{-4}{s(s+1)} = \frac{A}{s} + \frac{B}{s+1}$$

$$-4 = A(s+1) + Bs$$

$$\text{At } s=0$$

$$\boxed{-4 = A}$$

$$\text{At } s=-1$$

$$-4 = B(-1)$$

$$\boxed{B = 4}$$

$$\frac{6}{s(s+2)} = \frac{A}{s} + \frac{B}{s+2}$$

$$6 = A(s+2) + Bs$$

$$\text{At } s=0$$

$$\frac{6}{2} = \boxed{A = 3}$$

$$\text{At } s=-2$$

$$6 = B(-2)$$

$$\boxed{B = -3}$$


$$C[s] = \frac{-4}{s} + \frac{4}{s+1} + \frac{3}{s} - \frac{3}{s+2} = \frac{4}{s+1} - \frac{3}{s+2} - \frac{1}{s}$$

$$c(t) = (4e^{-t} - 3e^{-2t} - 1)u(t)$$

* Sensitivity (Imp)

- Sensitivity is nothing but variation in system output or system response due to parameter variations in

(i) $g(s)$ & (ii) $H(s)$



$$\frac{\delta G[s]}{G[s]} = \frac{\delta C[s]}{C[s]}$$

$$T_1 = 20^\circ\text{C}$$

$$T_2 = 25^\circ\text{C}$$

$$\text{Change in Temp.} = T_2 - T_1 = \Delta T$$

$$\% \text{ Change in Temp.} = \frac{\Delta T}{T_1} \times 100\%$$

$$\text{Let } T.F. = T$$

$$\% \text{ change in } T.F. = \frac{dT}{T} \times 100\%$$

$$\% \text{ change in } G = \frac{dG}{G} \times 100\%$$

$$\% \text{ change in } H = \frac{dH}{H} \times 100\%$$

$$\% \text{ change in } K = \frac{dK}{K} \times 100\%$$

$$S_a^T = \frac{\% \text{ change in } T.F.}{\% \text{ change in } G}$$

$$S_a^T = \frac{\frac{dT}{T}}{\frac{dG}{G}} = \frac{dT}{dG} \times \frac{G}{T}$$


$$\% S_a^T = \frac{dT}{dG} \times \frac{G}{T} \times 100\%$$

$$S_H^T = \frac{dT}{dH} \times \frac{H}{T}$$

$$S_K^T = \frac{dT}{dK} \times \frac{K}{T}$$

$$S_a^T = \frac{dT}{dG} \times \frac{G}{T}$$

* Open loop system



$$T.F. = T = \frac{C}{R} = G$$

$$\Rightarrow T = G$$


$$\frac{dT}{dG} = 1$$

$$(1) S_G^T = \frac{dT}{dG} \times \frac{G}{T}$$

$$S_G^T = 1 \times \frac{G}{G} = 1$$

$$\% S_G^T = 100\%$$

* Closed loop system



$$T = \frac{G}{1+GH} \Rightarrow \frac{dT}{dG} = \frac{(1+GH) \cdot 1 - G(H)}{(1+GH)^2} = \frac{1}{(1+GH)^2}$$

$$(1) S_G^T = \frac{dT}{dG} \times \frac{G}{T}$$

$$= \frac{1}{(1+GH)^2} \times \frac{G}{T}$$

$$= \frac{1}{(1+GH)^2} \times \frac{G(1+GH)}{G}$$

$$S_G^T = \frac{1}{1+GH} \Rightarrow S_G^T(\%) = \frac{1}{1+GH} \times 100\%$$

$$(2) S_H^T = \frac{dT}{dH} \times \frac{H}{T}$$

$$\frac{dT}{dH} = \frac{(1+GH)0 - G(a)}{(1+GH)^2}$$

$$\frac{dT}{dH} = \frac{-G^2}{(1+GH)^2}$$

$$S_H^T = \frac{-G^2}{(1+GH)^2} \times \frac{H(1+GH)}{a}$$

$$S_H^T = \frac{-GH}{1+GH}$$

$$S_H^T (\%) = \frac{-GH}{1+GH} \times 100\%$$

NOTE:-

Open loop

$$① S_a^T = 100\%$$

Close loop

$$① S_a^T = \frac{1}{1+GH} \times 100\%$$


$$② S_H^T = \frac{-GH}{1+GH} \times 100\%$$

- Close loop system is less sensitivity than open loop system due to parameter variation in $G(s)$ [i.e. forward path gain]

- Close loop system sensitivity is decreased by $1+GH$ factor wrt. G

- In close loop system, system response is more sensitivity due to parameter variation in feedback path gain compare to forward path gain G

Q:- Find the sensitivity of closed loop system w.r.t. variation in (1) k (2) a



Sol:- T.F. = $T = \frac{G}{1+GH}$

$$T = \frac{\frac{k}{s(s+a)}}{1 + \frac{k}{(s+a)s}} = \frac{k}{s(s+a) + k}$$

(1) $S_K^T = \frac{dT}{dK} \times \frac{K}{T}$

$$= \frac{(s(s+a)+k) \cdot 1 - k \cdot 1}{(s(s+a)+k)^2} \times \frac{k}{k}$$


$$= \frac{s(s+a)}{(s(s+a)+k)^2}$$

$$S_K^T = \frac{s(s+a)}{s(s+a)+k}$$

(2) $S_a^T = \frac{dT}{da} \times \frac{a}{T}$

$$= \frac{-k \cdot s}{(s(s+a)+k)^2} \times \frac{a(s(s+a)+k)}{k}$$

$$S_a^T = \frac{-as}{s^2+as+k}$$




$$\text{T.F.} = \frac{1}{1+sCR}$$

$$\text{Let } \tau = RC$$

$$\text{T.F.} = \frac{1}{1+s\tau}$$

No. of time constant $\tau = 1 = \text{No. of memory storage element}$

★ ★ Q:- Find no. of time constant



No. of time constant $= 2$

- First find equivalent when there is more than one inductor and capacitance present and find time constant.